

## San Diego Regional Water Quality Control Board

March 29, 2017

Mr. Wesley Fromlath  
Lilac Enterprise Corporation  
917 Seph Way  
Escondido, CA 92027

**In reply refer to / attn:**  
**230289:BBushnell**

**Subject: Review of Monitoring Reports for Order No. 93-27, Hideaway Lake Mobile Estates**

Mr. Fromlath:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the monitoring reports listed in the table below. The Lilac Enterprise Corporation (Discharger) submitted the monitoring reports as required by the Monitoring and Reporting Program No. 93-27

### List of Monitoring Reports Reviewed

Report Type	Report Date
Semiannual Monitoring Reports	January-June 2016 and July-December 2016
Annual Monitoring Reports	2016

Violations of Section B.1 (Discharge Specifications) of Order No. 93-27 were identified in the monitoring reports are described below:

1. The discharge specification for boron is established for a daily maximum concentration at 0.5 milligrams per liter (mg/L). This limitation was exceeded on October 3, 2016 with a value of 1.0 mg/L.

The San Diego Water Board has the following comments regarding the reports reviewed:


1. The boron discharge specification is listed at 0.75 mg/L in the monitoring report, however section B.1 (Discharge Specifications) of Order No. 93-27 establishes the boron discharge specification at 0.5 mg/L.
2. The next monitoring report due is the January-June 2017 semiannual report, which is due by July 30, 2017.

Please continue to implement follow-up actions necessary to ensure that the violations noted above do not occur in the future. These violations may subject the Discharger to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the Discharger to cease and desist from violations, or administrative assessments of civil liabilities in amounts of up to \$5,000 per day per violation;


referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution..

In the subject line of any response, please include reference **230289:BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at [brandon.bushnell@waterboards.ca.gov](mailto:brandon.bushnell@waterboards.ca.gov) if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G, Senior Engineering Geologist  
Land Discharge Unit



JRO: ac: bb

Tech Staff Info & Use	
Place ID	230289
Reg. Measure ID	142447
SEL Reg. Measure ID	412381
Violation ID	1022639