

Public SSO Statistics Summary for FY 2006-2007 (July 1 - June 30)

Sewer Agency (Sorted by County)	System Size		Total #	# SSO's	Total SSO	Total Volume	Total Volume	Percent
	(miles) ¹	(mgd) ²	of SSOs	per 100 mi	Volume	per Mgallon ³	Recovered	Recovered
Orange County								
Irvine Ranch Water District	36.024	2	0	0				
City of Laguna Beach	99.5	2.358	10	10.1	6,620	7.7	4,443	67.1%
City of San Clemente	185.0	4.480	5	2.7	6,610	4.0	4,280	64.8%
City of San Juan Capistrano	548.3	3.430	4	0.7	5,400	4.3	0	0.0%
El Toro Water District	65.1	2.227	2	3.1	273	0.3	0	0.0%
Emerald Bay Service District	6.5	0.094	0	0.0				
Moulton Niguel Water District	530.0	13.003	1	0.2	600	0.1	200	33.3%
Santa Margarita Water District	702.0	10.720	2	0.3	393,275	100.5	600	0.2%
South Coast Water District	138.2	3.961	3	2.2	1,150	0.8	300	26.1%
Trabuco Canyon Water District	47.0	0.720	5	10.6	200	0.8	0	0.0%
Riverside County								
Eastern Municipal Water District	1811.0	9.500	4	0.221	1,073,315	309.5	94,800	8.8%
Elsinore Valley	79.6	2.008	0	0				
Murrieta MWD	200.0	0.517	0	0				
Rancho California Water District	81.0	2.858	2	2.469	251,550	241.1	0	0.0%
San Diego County								
22ND District Agricultural Association	2.7	N/A	1	37.037	40	N/A	35	87.5%
Buena Sanitary District	197.9	1.860	0	0				
California Department of Corrections	N/A	N/A	0	0				
California State University, San Marcos	N/A	N/A	0	0				
Carlsbad Municipal Water District	410.8	7.200	6	1.461	7,337,279	2792.0	5,879,097	80.1%
City of Chula Vista	460.6	15.951	6	1.303	12,617	2.2	5,210	41.3%
City of Coronado	46.9	3.800	2	4.264	220,234	158.8	544	0.2%
City of Del Mar	30.8	1.132	1	3.247	100	0.2	100	100%
City of El Cajon	195.0	9.100	1	0.513	4,400	1.3	2,050	47%
City of Encinitas	119.0	4.111	1	0.840	200	0.1	200	100%
City of Escondido	370.7	10.847	7	1.888	7,440	1.9	1,375	18.5%
City of Imperial Beach	44.2	2.153	4	9.050	914	1.2	164	17.9%
City of La Mesa	155.0	5.830	0	0				
City of Lemon Grove	62.5	2.417	0	0				
City of National City	97.9	5.096	1	1.021	6,750	3.6	0	0.0%
City of Oceanside	475.0	13.000	5	1.053	32,370	6.8	31,305	96.7%

<i>Sewer Agency (Sorted by County)</i>	<i>System Size</i>		<i>Total #</i>	<i># SSO's</i>	<i>Total SSO</i>	<i>Total Volume</i>	<i>Total Volume</i>	<i>Percent</i>
	<i>(miles)</i> ¹	<i>(mgd)</i> ²	<i>of SSOs</i>	<i>per 100 mi</i>	<i>Volume</i>	<i>per Mgallon</i> ³	<i>Recovered</i>	<i>Recovered</i>
City of Poway	219.0	4.018	1	0.457	100	0.1	0	0%
City of San Diego	5004.0	170.136	18	0.360	225,231	3.6	77,318	34.3%
City of Solana Beach	45.0	1.2	1	2.2	2,000	4.5	2,000	100.0%
City of Vista	416.8	6.5	2	0.5	421,925	178.9	334,600	79.3%
County of San Diego	289.9	11.0	1	0.3	6,920	1.7	900	13.0%
Fairbanks Ranch Comm Serv District	15.5	0.2	0	0.0				
Fallbrook Public Utilities District	76.6	2.0	4	5.2	142,544	195.3	200	0.1%
Leucadia CWD	207.0	4.2	1	0.5	2,750	1.8	0	0.0%
Olivenhain Municipal Water District	35.5	0.4	1	2.8	300	2.1	300	100.0%
Otay Municipal Water District	81.6	1.4	1	1.2	100	0.2	0	0.0%
Padre Dam Municipal Water District	246.0	5.1	1	0.4	6625	3.6	6,000	90.6%
Pauma Valley Comm Services District	11.5	0.7	0	0.0				
Rainbow Municipal Water District	56.0	0.7	1	1.8	3000	11.2	0	0.0%
Ramona Municipal Water District	134.0	1.3	1	0.7	48646	102.6	0	0.0%
Rancho Santa Fe Comm Serv District	78.0	0.4	0	0.0				
San Diego State University	9.0	N/A	1	11.1	960	N/A	0	0.0%
University of California San Diego	30.0	N/A	1	3.3	1,700	N/A	0	0.0%
U.S. Marine Corps, Camp Pendleton	217.0	3.1	12	5.5	177,008	159	23,854	13.5%
U.S Marine Corps Recruit Depot	6.5	N/A	1	15.4	5	N/A	5	100.0%
U.S. Navy Public Works Center	122.8	4.0	3	2.4	14,228,816	9745.8	0	0.0%
Vallecitos Water District	202.0	6.1	1	0.5	37	0.0	0	0.0%
Valley Center Municipal Water District	70.0	0.3	1	1.4	250	2.1	150.0	60.0%
Whispering Palms Comm Serv District	25.0	0.3	0	0.0				
Total	14796.9	363.5	126	---	24,630,254	---	6,470,030	---
Average	290.1	7.9	---	2.8	---	390.3	---	34%

Notes:

1.- "Most of the Agencies' System Sizes are based on the online Collection System Questionnaires. The System Sizes for California State University San Marcos, US Navy, 22ND District Agricultural Association, and California Department of Corrections are based on the 2003 questionnaire or are not available (N/A) because these agencies have not completed the online Collection System Questionnaires. The System Sizes for El Toro Water District and Irvine Ranch Water District are based on the 2003 questionnaire because the online Collection System Questionnaires for these agencies includes the sewage collection system in Region 8 and 9. The System Sizes includes laterals that the agencies are responsible for and may not have been included in past reports."

2.- Average flow rate through collection system as of June 2003

3.- Volume of spills for the period in gallons divided by the amount conveyed for the period in million gallons