

**ERRATA SHEET NO. 2**

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
SAN DIEGO REGION**

**TENTATIVE ORDER NO. R9-2016-0183**

**MASTER RECYCLING PERMIT FOR CARLSBAD MUNICIPAL WATER DISTRICT  
CARLSBAD WATER RECYCLING FACILITY, SAN DIEGO COUNTY**

Errata No. 2 adds monitoring requirements for perchlorate in order to evaluate compliance with the discharge specification for perchlorate in Tentative Order No. R9-2016-0183.

The redline text shown below shall be added to Table 1 of Attachment D to Tentative Order No. R9-2016-0183 (Monitoring and Reporting Program) as follows:

**Table 1. Effluent Monitoring**

<b>Parameter</b>	<b>Units</b>	<b>Sample Type</b>	<b>Minimum Sampling Frequency<sup>a,b</sup></b>	<b>Reporting Frequency</b>
Aluminum	mg/L	Composite	Annually	Annually
Barium	mg/L	Composite	Annually	Annually
<u>Perchlorate</u>	<u>mg/L</u>	<u>Composite</u>	<u>Annually</u>	<u>Annually</u>
Priority Pollutants <sup>f</sup>	mg/L	Composite	Annually	Annually