



# California Regional Water Quality Control Board

## San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties

Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger  
Governor

Linda S. Adams  
Secretary for  
Environmental Protection

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353

(858) 467-2952 • Fax (858) 571-6972

[http:// www.waterboards.ca.gov/sandiego](http://www.waterboards.ca.gov/sandiego)

May 6, 2010

In reply refer to:  
224137:oosibodu

Mr. Joe Jackson  
Asst. General Manager  
Fallbrook Public Utility District  
990 East Mission Road  
P.O Box 2290  
Fallbrook, CA 92088-2290

Dear Mr. Jackson:

**SUBJECT: REVIEW OF MONITORING REPORTS FOR THE FALLBROOK PUBLIC UTILITY DISTRICT TREATMENT PLANT NO. 1**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the September 2009-March 2010 monthly monitoring reports; and the July-September 2009, October-December 2009, and January-March 2010 reclaimed water user's summary reports submitted by the Fallbrook Public Utility District in accordance with Order No. 91-39. The following violations of Discharge Specification B.1 of Order No. 91-39 were identified in the submitted reports:

The daily average effluent discharge specification for turbidity established at 2 Nephelometric Turbidity Units (NTU) was exceeded on November 8 and December 17, 2009 with reported values of 2.63 and 2.54 NTU respectively.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;<sup>1</sup> referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution

The next monitoring report required to be submitted is the April 2010 monthly monitoring report, which is due by May 30, 2010.

<sup>1</sup> Under authority of California Water Code section 13350.

