

San Diego Regional Water Quality Control Board

July 11, 2014

Ms. Yvette Montes
Barrett Lake Mobile Home Park
1250 Barrett Lake Rd
Dulzura, CA 91917

In reply refer to:
208749:acali

Subject: Review of the 2013 Annual Monitoring Report for Barrett Lake Mobile Home Park

Ms. Montes:

The California Regional Water Quality Control Board, San Diego Region has reviewed the 2013 annual monitoring report submitted by Barrett Lake Mobile Home Park in accordance with the Monitoring and Reporting Program of Order No. 94-142, and has the following comments:

1. The 2013 annual monitoring report states that your facility currently has 139 sewerer recreational vehicle (RV) spaces. The operation at the facility is no longer in compliance with Order No. 96-142 because the number of RV spaces have been increased from 76 to 139, which is more than 25 percent. Section B.6 (Discharge Specifications) of Order No. 94-142 requires that you submit a Report of Waste Discharge to the San Diego Water Board at least 120 days prior to increasing the number of sewerer RV spaces by more than 25 percent over the authorized capacity.

In order to come back into compliance with Order 94-142, you must either provide the San Diego Water Board with a Report of Waste Discharge (ROWD) that describes any expansions or modifications that have been made to the facility, the design/operation of the septic tank/leach field system to accommodate the additional RV spaces, or submit a report prepared by a registered civil engineer certifying that the existing facility septic tank/leach field system has sufficient capacity to serve the waste water treatment needs at the facility and comply with the wastewater treatment requirements specified in Order No. 94-142. If the existing waste water treatment system has been upgraded to accommodate the increased number of RV spaces, then a completed ROWD is required so that the San Diego Water Board can revise/renew the waste discharge requirements in Order No. 94-142.

2. Please provide the San Diego Water Board with a new ROWD by October 9, 2014.
3. The next monitoring report required to be submitted is the 2014 annual monitoring report, which is due January 30, 2015.


DR. HENRY ABARBANEL, CHAIR | DAVID GIBSON, EXECUTIVE OFFICER

2375 Northside Drive, Suite 100, San Diego, CA 92108-2700 | (619) 516-1990 | www.waterboards.ca.gov/sandiego



In the subject line of any response, please include reference **208749: acali**. Please contact Mr. Alex Cali at (619) 521-3355, or at acali@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G.,
Senior Engineering Geologist
Land Discharge Unit

JRO: ac

Tech Staff Info & Use	
Place ID	208749
Party ID	496236
Reg. Measure ID	142492