

California Regional Water Quality Control Board, San Diego Region

June 13, 2014

In reply refer to:
244506: lcanada

Mr. Robert Mulvey
Assistant Public Utilities Director
Water Quality Branch
City of San Diego
2392 Kincaid Road
San Diego, CA 92101

**Subject: Review of Monitoring Reports for North City Water Reclamation Plant
Order No. 97-03**

Mr. Mulvey:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April 2014 monthly monitoring report submitted by City of San Diego (City) in accordance with the Monitoring and Reporting Program of Order No. 97-03.

The submitted report identified the following violation of Section A.2 (Discharge Specifications) in Order No. 97-03:

The 12-month running average effluent limitation for manganese, established at 0.05 milligrams per liter (mg/L), was exceeded during April 2014, with a value of 0.0747 mg/L.


Please take steps to implement follow-up actions necessary to ensure that the violation noted above does not occur in the future. These violations subject the City to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the City to cease and desist from violations, or administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ referral to the State Attorney General for injunctive relief; and referral to the District Attorney for criminal prosecution.

The next monitoring report required to be submitted is the May 2014 monthly monitoring report, which is due by June 30, 2014.

¹ Under authority of California Water Code section 13350.

In the subject line of any response, please include reference **244506: Icanada**. Please contact Ms. Leah Canada at 619-521-8050, or at Leah.Canada@waterboards.ca.gov if you have any questions or comments.

Respectfully,



John R. Odermatt, P.G., Senior Engineering Geologist
Land Discharge Unit

JRO: oo: lc

Tech Staff Info & Use	
Place ID	244506
Reg. Measure ID	396697
Violation ID	970114