
California Regional Water Quality Control Board, San Diego Region

By Email Only

July 10, 2015

Ms. Sheila Henika
Environmental Engineer
Cabrillo Power I LLC
sheila.henika@nrgenergy.com

In reply refer to:
Place ID 222755:Bneill

Subject: Staff Enforcement Letter, 2014 and 2015 Self-Monitoring Reports (SMRs) for Encina Power Plant, Order No. R9-2006-0043, NPDES Permit No. CA0001350

Ms. Henika:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the following self-monitoring reports (SMRs) and technical reports submitted between January 2014 and April 2015 for the aforementioned facility:

- Monthly SMRs – February 2014 through April 2015
- Semi-annual SMRs - January 2014 through December 2014
- Annual SMRs - 2014

The following is a summary of the San Diego Water Board's findings:


1. Violation – Effluent Exceedance, Section IV.B.1

- a. The chronic toxicity daily maximum limitation of 16.5 TUc was exceeded on October 13, 2014 with a reported value of 33.3 TUc at Monitoring Location M-001.

Pursuant to the California Water Code (CWC), the violations noted are subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, imposition of administrative civil liability, referral to the district attorney for criminal prosecution, or referral to the attorney general. Administrative civil liability amounts that may be imposed by the San Diego Water Board under authority of CWC Section 13385 include up to \$10,000 per day, or up to \$10 per gallon for each gallon of waste discharged.

In the subject line of any response, please include the reference "Place ID 222755:Bneill". For questions or concerns regarding this letter, please contact Ben Neill at 619-521-3376 or ben.neill@waterboards.ca.gov.

Respectfully,



Ben Neill, P.E.
Water Resources Control Engineer
Source Control Unit

Tech Staff Info & Use	
Order No.	R9-2006-0043
WDID	9 000000092
NPDES No.	CA0001350
Reg. Measure ID	308204 (R9-2006-0043)
Place ID	222755
Enforcement ID	401641
Violation ID(s)	985285