



## San Diego Regional Water Quality Control Board

## Sent Via Email Only

September 30, 2015

Mr. Andrew Entingh
Head, Environmental Engineering Department
Environmental Security
Marine Corps Base, Camp Pendleton
BOX 555008
Camp Pendleton, CA 92055
andrew.entingh@usmc.mil

In reply refer to: 638334:JLLim

Subject:

Staff Enforcement Letter for Southern Regional Tertiary Treatment Plant, Order

No. R9-2013-0112, NPDES Permit No. CA0109347

Mr. Entingh:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has noted the following violations and has the following comments for the Southern Regional Tertiary Treatment Plant:

## Violation – Receiving Water Exceedance, Section V.A.1.a

- **1.** The fecal coliform single sample maximum limit of 400 MPN/100 mL was exceeded on May 4, 2015 with a reported value of 1600 MPN/100 mL at Monitoring Location A2.
- 2. The fecal coliform single sample maximum limit of 400 MPN/100 mL was exceeded on June 1, 2015 with a reported value of 700 MPN/100 mL at Monitoring Location A3.

Pursuant to the California Water Code (CWC), the violations noted are subject to additional enforcement action(s) by the San Diego Water Board including a time schedule order, cease and desist order, cleanup and abatement order, referral to the district attorney for criminal prosecution, or referral to the attorney general.

Mr. Entingh
Environmental Security
Marine Corps Base, Camp Pendleton

In the subject line of any response, please include the reference "Place ID 638334:JLLim". For questions or concerns regarding this letter, please contact Joann Lim at 619-521-3362 or joann.lim@waterboards.ca.gov.

Respectfully,

Dat Quach, P.E.

Water Resource Control Engineer

Source Control Unit

Tech Staff Info & Use	
Order No. Party IDs WDID NPDES No. Reg. Measure IDs PIN	R9-2013-0112 511527 (Camp Pendleton), 358301 (Entingh) 9 000001182 CA0109347 391013 ( R9-2013-0112), 402604 (SEL) 638334
Violation IDs	
1. 2.	992426 994016