

**San Diego Regional Water Quality Control Board**

April 28, 2017

Mr. Jesselton Gregorio  
Marine Corps Recruit Depot  
Environmental Office  
4600 Belleau Avenue, Building 224  
San Diego, CA 92140

**In reply refer to / attn:**  
**800459:BBushnell**

**Subject: Review of Monitoring Reports for Order WQ 2014-0153-DWQ, Marine Corps Recruit Depot Onsite Wastewater Treatment System**

Mr. Gregorio:

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the monitoring reports listed in the Table 1 below. The United States Marine Corps (Discharger) submitted the monitoring reports as required by the Monitoring and Reporting Program of Order WQ 2014-0153-DWQ.

**Table 1. List of Monitoring Reports Reviewed**

Report Type	Report Date
Quarterly Monitoring Reports	January-March 2016, April-June 2016, July-September 2016 and October-December 2016
Annual Monitoring Reports	2016 Annual report

The following violations of Effluent Limitations in Order WQ 2014-0153-DWQ section D.1 were identified in the monitoring reports:

1. The discharge specification for the monthly average effluent concentration of total suspended solids (TSS) established at 30 milligrams per liter (mg/L) was exceeded on February 11, 2016 and December 19, 2016 with reported concentrations of 37.3 mg/L and 92.7 mg/L, respectively.
2. The discharge specification for the daily maximum effluent concentration of TSS established at 45 mg/l was exceeded on December 19, 2016 with a reported concentration of 92.7 mg/L.


Please implement follow-up actions necessary to ensure that the violations noted above do not occur in the future. These violations may subject the Discharger to possible further enforcement action by the San Diego Water Board including but not limited to: administrative enforcement orders requiring the Discharger to cease and desist from

violations, referral to the State Attorney General for injunctive relief; or other legal actions as allowed by federal law.


The next monitoring report required to be submitted is the January-March quarterly monitoring report, which is due by April 30, 2017.

In the subject line of any response, please include reference **800459:BBushnell**. Please contact Mr. Brandon Bushnell at 619-521-8044, or at [brandon.bushnell@waterboards.ca.gov](mailto:brandon.bushnell@waterboards.ca.gov) if you have any questions or comments.

Sincerely,



John R. Odermatt, P.G., Senior Engineering Geologist  
Land Discharge Unit



JRO: oo: bb

Tech Staff Info & Use	
Place ID	800459
Reg. Measure ID	393782
SEL ID	412553
Violation ID	1023164, 1023168, 1023169