

ITEM NO. *8

December 2, 2022

ERRATA SHEET

CHANGES TO TENTATIVE ORDER NO. R8-2022-0050

WASTE DISCHARGE REQUIREMENTS AND
MASTER RECYCLING PERMIT
FOR THE
ORANGE COUNTY WATER DISTRICT
GROUNDWATER REPLENISHMENT SYSTEM

(Language added is **bold and underlined**; language deleted is ~~strike through~~)

(note - upon Order adoption, errata will be incorporated and in the finalization of the document, formatting and minor typographical corrections will be made; further, non-substantive changes may be made to improve readability in compliance with California Government Code section 11546.7 document accessibility requirements)

1. Order No. R8-2022-0050, Order, Table 10, page 16; modify the NL for Perfluorohexanesulfonic acid (PFHxS) and Perfluorooctanesulfonic acid (PFOS), as follows:

Parameter	Units	NL	RL
Boron	mg/L	1	10
n-Butylbenzene	"	0.26	2.6
...
Perfluorohexanesulfonic acid (PFHxS)	"	0.000002 <u>0.000003</u>	0.00002
Perfluorooctanesulfonic acid (PFOS)	"	0.000065 <u>0.000065</u>	0.00004
...

2. Order No. R8-2022-0050, Attachment E, Monitoring Requirements, page 8 and 9, modify Section IV.C.1., as follows:

1. If the annual average of the results of the monitoring performed exceeds a parameter's secondary MCL **in title 22 Table 64449-A or upper limit in title 22 Table 64449-B**, the Discharger shall initiate quarterly monitoring for the parameter and if the running annual average of quarterly-averaged results exceeds a parameter's secondary MCL **or upper limit**, describe the reason(s) for the exceedance and any corrective action taken in a report that must be submitted to the Santa Ana Water Board and DDW no later than 45 days following the quarter in which the exceedance occurred. The annual

KRISTINE MURRAY, CHAIR | JAYNE JOY, EXECUTIVE OFFICER

monitoring frequency may resume if the running annual average of quarterly results does not exceed a parameter's secondary MCL or upper limit.

3. Order No. R8-2022-0050, Attachment E, Monitoring Requirements, page 10, modify Section IV.F.1.b., as follows:
 - b) If the average of the initial and confirmation sample exceeds the parameter's MCL or AL, or a confirmation sample is not collected and analyzed, the Discharger must initiate weekly monitoring for the parameter until four consecutive weekly results are below the parameter's MCL or AL. The Discharger must notify the Santa Ana Water Board and DDW within 24 hours if ~~any sample~~ **the average of the initial and confirmation samples** exceeds an MCL or AL, **or if a confirmation sample is not collected**.

4. Order No. R8-2022-0050, Attachment E, Monitoring Requirements, page 10, modify Section IV.F.2.b., as follows:
 - b) If the average of the initial and confirmation sample exceeds the parameter's MCL, or a confirmation sample is not collected and analyzed, the Discharger must initiate weekly monitoring for the parameter until the running four-week average no longer exceeds the MCL. ~~The Discharger must notify the Santa Ana Water Board and DDW within 24 hours if any sample exceeds an MCL.~~