

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location | Spill Type | Volume Spilled | Description of Incident |
|---------------|---------------|------------|--------------------------|--|------------|----------------|--|
| 3/5/01 | 3/5/01 | 10787 | City of Fullerton | Between Domingo Rd. & Miguel Pl., Fullerton, Orange County | SSO | 500 | Approximately 500 gallons of sewage overflowed from a manhole due to a root blockage. About 250 gallons of the spill were contained, recovered, and returned to the operational sewer system, while the rest of the spill discharged into a storm drain catch basin. The blockage was cleared and the area was cleaned up by City of Fullerton staff. |
| 3/12/01 | 3/12/01 | 10806 | Private Party | 1401 Avocado Ave., Newport Beach, Orange County | SSO | 1,000 | An estimated 1,000 gallons of sewage overflowed from a private manhole due to line blockage. Approximately 700 gallons of the spill were contained, recovered, and returned to the operational sewer system. 300 gallons of the spill were discharged into a local storm drain which flowed to Newport Bay. As a result, OCHCA closed a section of beach. The blockage was cleared, and the affected area was cleaned up by City of Newport Beach staff. |
| 3/22/01 | 3/22/01 | 12037 | City of Huntington Beach | 6301 Braemar Dr., Huntington Beach, Orange County | SSO | 3,000 | An estimated 3,000 gallons of sewage overflowed from a manhole due to unknown blockage. The entire spill discharged into a local storm drain tributary to the Slater Channel storm water facility, where it was contained and a sample taken for analysis. The results of analysis indicated no contamination. The contained water was then released into the E. Garden Grove - Wintersburg flood control channel, which discharges into Outer Bolsa Bay and Huntington Harbour. |

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location | Spill Type | Volume Spilled | Description of Incident |
|---------------|---------------|------------|----------------------------------|--|------------|----------------|---|
| 3/31/01 | 3/31/01 | 11539 | Cucamonga County Water District | 2059 Yale St., Ontario, San Bernardino County | SSO | 1,800 | An estimated 1,800 gallons of sewage overflowed from a manhole due to a grease blockage. The entire spill was contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by CCWD staff. |
| 4/8/01 | 4/8/01 | 12034 | Yorba Linda Water District | Behind Pinewood Apartments, Avocado Ave., Yorba Linda, Orange County | SSO | 4,725 | An estimated 4,725 gallons of sewage overflowed from a manhole due to a sewer line blocked with pieces of concrete, due to vandalism. The entire spill discharged to a drainage swale and entered a local storm water containment basin (Yorba Linda Lakebed) where it percolated into the ground. YLWD excavated the blocked section of sewer line, and removed and replaced it. The affected area was cleaned up and disinfected by YLWD's staff. |
| 4/10/01 | 4/10/01 | 11662 | Eastern Municipal Water District | Between Pigeon Pass Ave. & Cougar St., Moreno Valley, Riverside County | SSO | 1,000 | Approximately 1,000 gallons of sewage overflowed from a manhole due to blockage caused by vandalism. The sewage was released into a vacant field. An unspecified amount was contained, recovered, and returned to the operational sewer system. The rest of the spill percolated into the ground. The blockage was cleared and the affected area was cleaned up and disinfected by EMWD's staff. |

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location | Spill Type | Volume Spilled | Description of Incident |
|---------------|---------------|------------|----------------------------------|---|------------|----------------|---|
| 4/11/01 | 4/10/01 | 12032 | Eastern Municipal Water District | Homeland Lift Station, 33570 Stetson Ave., Homeland, Riverside County | SSO | 5,000 | An estimated 5,000 gallons of sewage overflowed from a lift station wet well due to a bypass hose failure. The spill entered a dry wash where it was contained, recovered, and returned to the wet well. The affected area was chlorinated and cleaned up by EMWD's staff. |
| 4/13/01 | 4/10/01 | 11841 | Eastern Municipal Water District | Pioneer Ridge Rd., Moreno Valley, Riverside County | SSO | 980 | An estimated 980 gallons of sewage overflowed from a manhole due to an unknown blockage. About 600 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill percolated into the ground. The affected area was cleaned up and disinfected by EMWD's staff. |
| 4/12/01 | 4/12/01 | 12033 | Private Party | 2130 W. Crescent Ave, Anaheim, Orange County | SSO | 1,000 | An estimated 1,000 gallons of sewage overflowed from a private lateral due to a grease blockage. All 1,000 gallons of the spill percolated into the soil. The blockage was cleared, and the affected area was cleaned up and disinfected by City of Anaheim staff. |
| 4/16/01 | 4/16/01 | 11535 | Eastern Municipal Water District | Between Day St. and Cottonwood Ave., Moreno Valley, Riverside County | SSO | 10,000 | An estimated 10,000 gallons of sewage was spilled due to a ruptured force main. The cause of the rupture is under investigation. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system. The rest of the spill was discharged into a local storm drain where it percolated. EMWD's staff repaired the force main and cleaned up the affected area. |

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location | Spill Type | Volume Spilled | Description of Incident |
|---------------|---------------|------------|------------------------------|---|------------|----------------|--|
| 4/18/01 | 4/17/01 | 11402 | City of Ontario | 300 E. Plaza Serena, Ontario, San Bernardino County | SSO | 1,000 | An estimated 1,000 gallons of sewage overflowed from a manhole due to an unknown blockage. The entire spill was contained with sandbags, recovered, and returned to the operational sewer system. The blockage was cleared, and the affected area was washed down and vacuumed by City of Ontario staff. |
| 4/17/01 | 4/17/01 | 12044 | Private Party | BNSF tracks @ Santa Fe Wy. (Mile Post 0.3), San Bernardino, San Bernardino County | SSO | 1,000 | An estimated 1,000 gallons of sewage overflowed from a manhole due to a blockage of debris and concrete pieces. The spill was contained between railroad tracks and a dirt parking lot, where it percolated into the ground. The affected area was cleaned up and disinfected by City of Colton staff. |
| 4/17/01 | 4/17/01 | 12023 | City of Anaheim | 558 S. Anaheim Blvd., Anaheim, Orange County | SSO | 1,000 | An estimated 1,000 gallons of sewage overflowed from a manhole due to a grease blockage. An unspecified amount of the spill was contained, recovered, and returned to the operational sewer system. The blockage was cleared, and the affected area cleaned up and disinfected by City of Anaheim staff. |
| 4/25/01 | 4/25/01 | 12042 | Private Party (Hilton Hotel) | 777 W. Convention Wy., Anaheim, Orange County | SSO | 2,400 | An estimated 2,400 gallons of sewage overflowed from a private lateral due to a grease blockage. About 1,200 gallons of the sewage were contained, recovered, and returned to the operational sewer system. The rest of the spill discharged into a local storm drain. The blockage was cleared and the affected area was cleaned up and disinfected by City of Anaheim staff. |

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location | Spill Type | Volume Spilled | Description of Incident |
|---------------|---------------|------------|----------------------------------|--|------------|----------------|---|
| 4/27/01 | 4/27/01 | 12027 | Private Party (mobile home park) | Between Santiago Dr. and Kitching St., Moreno Valley, Riverside County | SSO | 3,000 | An estimated 3,000 gallons of sewage overflowed from a private manhole, due to an 8" lateral blocked with grease. 2,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The rest of the spill was not recoverable and percolated into the ground. EMWD's staff removed the blockage, and cleaned up and disinfected the affected area. |
| 4/27/01 | 4/27/01 | 12040 | City of Riverside | 3198 Redwood Dr., Riverside, Riverside County | SSO | 489 | An estimated 489 gallons of sewage overflowed from a manhole due to a grease blockage. The spill discharged into a local storm drain and subsequently percolated into the ground. Repairs were made, the blockage was cleared, and the cleanup of the affected area was completed by City of Riverside staff. |
| 4/30/01 | 4/30/01 | 12029 | Private Party (business park) | 4290 Katella Ave., Los Alamitos, Orange County | SSO | 2,000 | An estimated 2,000 gallons of sewage overflowed from a private lateral due to a grease blockage. The lateral serves a number of businesses. 1,940 gallons of the spill were contained, recovered, and returned to the operational sewer system. 60 gallons of the spill were not recovered and discharged into a local storm drain. LAPWD's staff removed the blockage, and cleaned up and disinfected the affected area. |

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (500 GALLONS AND ABOVE)

| Reported Date | Date of Spill | Notif. No. | Responsible Party | Incident Location | Spill Type | Volume Spilled | Description of Incident |
|---------------|---------------|------------|-------------------|---|------------|----------------|--|
| 5/9/01 | 5/5/01 | 11963 | EMWD | Rowe Dr. and Cockatiel Dr., Moreno Valley, Riverside County | SSO | 1,650 | An estimated 1,650 gallons of sewage overflowed from a manhole due to a grease blockage at a junction of 8" sewer lines. The spill entered a storm drain, and an unlined flood channel, where the spill percolated into the ground. The line was jetted to clear the obstruction, and lime was applied to the affected area by EMWD's staff. |