

Summary Report of Hazardous Waste and Sewage Spill Incidents per Water Code Section 13271

I. Petroleum Products

Date Reported*	Date Discovered	Location	Discharger	Problem	Action
3/20/2001	3/20/2001	213 W Valley Blvd., Rialto	CHEM TRANS, INC.	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
3/12/2001	11/22/2000	16090 Foothill Blvd., Fontana	ARCO PRODUCTS COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
5/16/2001	12/6/2000	2662 E Walnut Ave., Ontario	CHINO BASIN WATER DISTRICT	UNDERGROUND STORAGE TANK LEAK: DIESEL CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
7/11/2001	3/23/2001	2105 E Florida Ave., Hemet	ARCO PRODUCTS COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
12/2/1998	12/2/1998	13361 Harbor, Garden Grove	ARCO PRODUCTS COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
12/19/2000	7/12/2000	2446 S. Archibald, Moreno Valley	ARCO PRODUCTS COMPANY	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
3/2/2001	3/2/2001	24440 Alessandro Blvd., Moreno Valley	MOBIL OIL CORPORATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS
4/3/2001	4/3/2001	12625 Fredrick St., Moreno Valley	MOBIL OIL CORPORATION	UNDERGROUND STORAGE TANK LEAK: GASOLINE CONTAMINATED SOIL	INVESTIGATION IN PROGRESS

*Report date is the date on the Unauthorized Release Report which is filled out by the local agency or the discharger.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (BEACH CLOSURES, AND SPILLS OF 500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
7/12/01	6/22/01	14015	Private Party	1200 South Standard, Santa Ana, Orange County	SSO	1,200	An estimated 1,200 gallons of sewage overflowed from a 4" private lateral due to an oil/grease blockage. All 1,200 gallons of the spill were contained, recovered, and returned to the operational sewer system. City of Santa Ana staff assisted the private contractor in removing the blockage, cleaning up, and disinfecting the affected area.
7/4/01	7/4/01	16847	City of Newport Beach	Ford/Jamboree, Newport Beach, Orange County	SSO	700	An estimated 700 gallons of sewage overflowed from a manhole due to a sewer line blockage caused by roots and grease. Approximately 200 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was cleared, the affected area cleaned up, and disinfected by the City of Newport Beach staff.
7/9/01	7/9/01	16975	Private Property Owner	141 W Lambert, La Habra, Orange County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a private lateral due to an unspecified blockage. All 1,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared, the affected area cleaned up, and disinfected by City of La Habra staff.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (BEACH CLOSURES, AND SPILLS OF 500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
8/23/01	8/23/01	16861	Private Property Owner	Katella & Douglas, Anaheim, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from an unspecified private property due to a grease blockage. Approximately 480 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged to a local storm drain. Blockage was cleared, the affected area cleaned up, and disinfected by the private property owner.
8/24/01	8/24/01	16842	City of Santa Ana	1900 W. First St., Santa Ana, Orange County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a broken sewer line. All 2,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. City of Santa Ana staff repaired the sewer line, cleaned up, and disinfected the affected area.
8/30/01	8/30/01	16933	Private Property Owner	Warner and Pacific Coast Highway, Huntington Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private lateral due to grease blockage. All 500 gallons discharged into a nearby storm drain which ran into Huntington Harbor. The blockage was cleared and the affected area was cleaned up by private property owner.
8/30/01	8/30/01	16951	Private Party, Jewel Land Company	17196 Pacific Coast Highway, Huntington Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private clean-out due to a blockage caused by debris. Approximately 50 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged to a nearby storm drain and flowed to Huntington Harbor. The blockage was cleared, the affected area cleaned up, and disinfected by the private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (BEACH CLOSURES, AND SPILLS OF 500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/1/01	9/1/01	16937	Cucamonga County Water District	Church Street, between Miliken Ave. & Rochester Ave., Rancho Cucamonga, San Bernardino County	SSO	2,190	An estimated 2,190 gallons of sewage overflowed from a manhole due to a blockage. Debris accumulated in an 8" sewer line in the District's sewer system. All 2,190 gallons of the spill discharged to a local storm drain and flowed to Deer Creek Channel. The blockage was cleared, the affected area cleaned up, and disinfected by Cucamonga County Water District.
9/2/01	9/2/01	16835	Private Party, Hometown Buffet	10910 Foothill Blvd., Rancho Cucamonga, San Bernardino County	SSO	2,000	An estimated 2,000 gallons of sewage overflowed from a private manhole (Hometown Buffet). All 2,000 gallons of the spill were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by the Cucamonga County Water District.
9/8/01	9/8/01	16896	Ocean Aire Apts., Private Party	7811 Talbert Ave, Huntington Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a private lateral due to unspecified blockage. Approximately 100 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged to a local storm drain. The blockage was cleared, affected area cleaned up, and disinfected by the private property owner.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (BEACH CLOSURES, AND SPILLS OF 500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
9/13/01	9/12/01	16852	Private Property Owner	1460 S. Harbor, Anaheim, Orange County	SSO	600	An estimated 600 gallons of sewage overflowed from an unspecified private property due to grease blockage. Approximately 200 gallons of the spill were contained, recovered, and returned to the operational sewer system while the rest of the spill discharged into a local storm drain. The blockage was cleared, the affected area cleaned up, and disinfected by private property owner.
9/13/01	9/13/01	16929	City of Orange	2393 N Tustin, Orange, Orange County	SSO	1,000	An estimated 500 to 1,000 gallons of sewage overflowed from a manhole due to a grease blockage. All of the spill discharged to a local storm drain which emptied into the Santa Ana River. The blockage was cleared, and the affected area was cleaned up by City of Tustin staff.
9/20/01	9/20/01	17559	Private Property Owner	17631 Fitch St, Huntington Beach, Orange County	SSO	500	An estimated 500 gallons of sewage overflowed from a manhole due to unspecified blockage. All 500 gallons of sewage were contained, recovered, and returned to the operational sewer system. The blockage was cleared and the affected area was cleaned up by City of Huntington Beach staff.
9/28/01	9/27/01	17783	Costa Mesa Sanitary District	215 Mesa Drive, Costa Mesa, Orange County	SSO	1,600	An estimated 1,600 gallons of sewage overflowed from a manhole due to unknown blockage. None of the spill was recovered. The sewage discharged into a local storm drain. The spill flowed to Santa Ana Country Club Lake on a golf course. The blockage was cleared, the affected area cleaned up, and disinfected by CMSD.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (BEACH CLOSURES, AND SPILLS OF 500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/2/01	9/24/01	17887	City of La Habra	601 W. Imperial HWY, La Habra, Orange County	SSO	3,750	An estimated 3,750 gallons of sewage overflowed from a manhole due to debris blockage. 1,650 gallons of the spill were contained, recovered, and returned to the operational sewer system. 2,100 gallons of the spill were not recovered and discharged to a local storm drain and flowed to Seal Beach. OCHCA closed a portion of Seal Beach and health warnings were posted. The debris was removed, the affected area cleaned up, and disinfected by the City of La Habra.
10/2/01	10/1/01	17789	East Valley Water District	4th Street & Del Rosa Drive, Highland, San Bernardino County	SSO	1,000	An estimated 1,000 gallons of sewage overflowed from a manhole due to debris blockage. None of the spill was recovered. The sewage discharged into an open field. The blockage was cleared, the affected area cleaned up, and disinfected by East Valley Water District staff.
10/3/01	10/3/01	17790	De Anza Marina, Private Owner	De Anza Marina Dock, Newport Beach, Orange County	SSO	50	An estimated 50 gallons of sewage was released from a broken 4" sewer line at pump-out station in De Anza Marina Dock. All 50 gallons of the spill discharged into Newport Bay. OCHCA closed the harbor water area at De Anza Marina in Newport Bay to swimming and diving due to this spill. The sewer line was repaired by private contractor.

SANTA ANA REGIONAL WATER QUALITY CONTROL BOARD

SEWAGE SPILL INCIDENTS (BEACH CLOSURES, AND SPILLS OF 500 GALLONS AND ABOVE)

Reported Date	Date of Spill	Notification No.	Responsible Party	Incident Location	Spill Type	Volume Spilled	Description of Incident
10/5/01	10/5/01	17884	Balboa Bay Club	Balboa Bay Club, Newport Beach, Orange County	SSO	50	An estimated 50 gallons of sewage was released from a broken 4" PVC sewer line at vessel pump-out station at Balboa Bay Club. All 50 gallons of the spill discharged into the bay. OCHCA closed the Newport Bay water area from "B" through "H" Docks, the beach at the Balboa Bay Club, and the Orange Coast College Crew Dock. The sewer line was repaired by a private contractor.