

# Ethanol

Manufacturer's Affirmative Statement of Compatibility  
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years Manufactured	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
Containment Solutions (previously Fluid Containment)	Double-Wall fiberglass tank	tank	UL file# MH7991	1995 - 2012 (present)	550 - 50,000 gallons	UL unique number label	0-100% and all blends between	No
Containment Solutions (previously Fluid Containment)	Double-wall transition sump	transition sump	UL file# MH29555	2004 - 2012 (present)	42" dia. 48" dia.	UL mark	0-100% and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall tank sump	tank top sump	UL file# MH29555	2004 - 2012 (present)	42" dia. 48" dia.	UL mark	0-100% and all blends between	
Containment Solutions (previously Fluid Containment)	HydroGuard® System	tank and tank top sump	UL file# MH7991	2004 - 2012 (present)	tank: 550 - 50,000 gallons sump: 42", 48"	registered trademark on tank; UL unique number label	0-100% and all blends between	
Containment Solutions (previously Fluid Containment)	Triple-Wall fiberglass tank	tank	UL file# MH7991	1997 - 2012 (present)	550 - 50,000 gallons	UL unique number label	0-100% and all blends between	
Containment Solutions (previously Fluid Containment)	ReTank®	in situ tank upgrade	UL file# MH25159	1996 - 2012 (present)	8' dia. tanks 4,000 - 15,000 gallons	proprietary panel design	0-100% and all blends between	
Containment Solutions (previously Fluid Containment)	Double-Wall transition sump	transition sump		June 2012	54" dia.		0-100% and all blends between	
Containment	Double-Wall tank	tank top		June 2012	54" dia.		0-100% and	

❖ Please complete and submit form to Cory Hootman of the SWRCB at [chootman@waterboards.ca.gov](mailto:chootman@waterboards.ca.gov).

# Ethanol

Manufacturer's Affirmative Statement of Compatibility  
 (As required by California Code of Regulations section 2631(k))

Solutions (previously Fluid Containment)	sump	sump					all blends between
Containment Solutions (previously Fluid Containment)	Double-Wall tank sump upgrade	transition sump	June 2012	42" dia. 48" dia.			0-100% and all blends between
Containment Solutions (previously Fluid Containment)	Double-Wall tank sump upgrade	tank top sump	June 2012	42" dia. 48" dia.			0-100% and all blends between

For tanks and piping please list only double wall products

(Insert a company logo below if available)



Manufacturer: Containment Solutions  
 Corporate 5150 Jefferson Chemical Road  
 Headquarters Conroe, TX 77301  
 Address:  
 Phone: 877-CSE-TANK  
 Email: sales@csiproducs.com

I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

David Helman  
 Print Name  
  
 Manufacturer's Authorized Signature

Director of Marketing  
 Title  
 5/1/2012  
 Date

❖ Please complete and submit form to Cory Hootman of the SWRCB at [chootman@waterboards.ca.gov](mailto:chootman@waterboards.ca.gov).