

Lubrizol Fuel Additive

Manufacturer's Affirmative Statement of Compatibility
(As required by California Code of Regulations section 2631(k))

Manufacturer(s) (including prior marketed names)	Model	Component Type (i.e. pipe, tank, etc.)	Current UL Standard Listing	Years of Manufacture	Sizes	Unique Identifiers for Field Evaluation (i.e. color, material)	Blend Concentration	Supporting Test Data & Documents Attached
Containment Solutions, Inc.	Additive-DWT6 Double-Wall fiberglass tank and sump for Lubrizol fuel additive storage	tank	UL file # MH7991	2011 - present	550 - 50,000 gallons	UL unique number label, Additive-DWT6 label	0-100% and all blends between	No
Containment Solutions, Inc.	Double-Wall tank sump upgrade	tank sump upgrade		2012-present	42" dia. 48" dia. 54" dia.	Additive label	0-100% and all blends between	No

For **tanks and piping** please list only double wall products

(Insert a company logo below if available)



Manufacturer: Containment Solutions, Inc.
 Corporate: **5150 Jefferson Chemical Rd**
 Headquarters: **Conroe, TX 77301**
 Address:
 Phone: 877-CSI-TANK
 Email: sales@csiproducts.com

I declare, to the best of my knowledge and belief, that this affirmative statement of compatibility and the information contained herein is true, correct, and complete.

David Heiman

Director of Marketing

Print Name

Title

Manufacturer


11/28/2012

Date

Containment Solutions, Inc.

Costco Additive Tank and Placement of Additive Label L20164

L20164 Model DWT6 – 1500 Gallon Capacity



Tank Model: (Modèle de Réservoir)	
<input type="checkbox"/>	Petroleum - DWT6
<input type="checkbox"/>	DEF - DWT6
<input checked="" type="checkbox"/>	Additive - DWT6
Compartment Capacity (Compartment Capacité)	
1,500	<input checked="" type="checkbox"/> Gal <input type="checkbox"/> Liter
<small>Containment Solutions, Inc. • L20164 • 09/2012</small>	