
State Water Resources Control Board

Consideration and Adoption Memo

Project Title: Jeffries Tank and Plant Improvements Project

Water System Number: 1910212

State Clearinghouse Number: 2022070277

Project Location: 124 West Jeffries Avenue in the City of Monrovia, California 91016. APN: 8511-015-800, 801. A portion of the site is located within unincorporated Los Angeles County. The site is located within Section 2, Township 1 South, Range 11 West, San Bernardino meridian of the U.S. Geological Survey (USGS) 7.5-minute Series El Monte Topographic quadrangle.

Applicant: Golden State Water Company (GSWC) – South Arcadia

Project Description: The State Water Resources Control Board (State Water Board) will be issuing a water supply permit amendment to the GSWC – South Arcadia for the proposed Project. The Project involves installation of a 1.25 million gallon (MG) above ground potable water storage tank, three booster pumps within a new block building, a new block disinfectant building, and associated fencing, landscaping, lighting, control panels and appurtenances at the existing Jeffries Plant site. Existing plant site piping will be modified as needed and the existing fencing, storage building, chemical building and MCC will be demolished. The existing Jeffries Well 4 currently pumps directly into the distribution system; after the project, this well will pump into the proposed tank. The Project would also replace approximately 1,000 feet of existing 8-inch steel water main with a 12-inch PVC water main in Jeffries Avenue from approximately Treelane Avenue to Peck Road.


Determination: The State Water Board, as lead agency in accordance with provisions of the California Environmental Quality Act (CEQA), has reviewed the Mitigated Negative Declaration (MND) for the above Project dated July 15, 2022.

The MND was circulated through the State Clearinghouse (SCH# 2019011048) for a 30-day review period beginning July 15, 2022 and ending August 16, 2022. One written comment was received during the public review period.

The State Water Board has considered the MND and Mitigation Monitoring and Reporting Plan (MMRP) together with all comments received during the environmental

review period. The State Water Board finds, on the basis of the whole record before it, that there is no substantial evidence that the Project will have a significant effect on the environment.

The State Water Board hereby adopts the MND and MMRP for the Project pursuant to the CEQA Guidelines, Section 15074(b).

Signature: 

Date: 09/1

Dmitriy Ginzburg, P.E.
District Engineer
Hollywood District 07
Division of Drinking Water
State Water Resources Control Board