


Public Works Services Department




Public Comment
Sanitary Sewer System WDRs
Deadline: 5/13/11 by 12 noon

Municipal Service Center
1400 Broadway Street
Redwood City, CA 94063-2505
Telephone: (650) 780-7464
Fax: (650) 780-7445
Internet: www.redwoodcity.org

May 13, 2011

Via email: commentletters@waterboards.ca.gov

Jeanine Townsend
Clerk to the Board
State Water Resources Control Board
1001 I Street, Sacramento, CA 95814



Subject: Comment Letter – SSS WDRs Review & Update

Dear Ms. Townsend:

The City of Redwood City appreciates the opportunity to comment on the State Water Quality Control Board's proposed revisions to the Sanitary Sewer System Waste Discharge Requirements (SSS WDRs).

The City of Redwood City is a charter city located in San Mateo County with a population of approximately 78,000 people. Our sanitary sewer collection system is 197 miles with 14,400 service laterals. Over the past several years, Redwood City has worked diligently to reduce the number preventable SSOs in our community through frequent and targeted preventative maintenance practices; annual system assessments based on accepted industry standards; an annual Capital Improvement / Replacement Program (CIP) projects; Fats, Oils & Grease (FOG) inspections of food service establishments (FSE); and public education of homeowners and businesses through mailings and the city website.

The proposed revisions to the SSS WDRs represent a major departure from the program that has been successfully implemented under the existing SSS WDRs. While we appreciate the State Water Board's efforts to address certain issues associated with the existing WDRs, our agency is very concerned about a number of the proposed revisions, especially those related to reporting of private lateral sewage discharges (PLSDs), and onerous additions to sewer system management plan (SSMP) requirements that should not be mandated unless State Water Board guidance and funding is made available. Also, we strongly oppose to including a NPDES permitting approach.

1. Sanitary sewer system regulations should not be adopted under a two-tiered WDRs and NPDES permit.

We strongly oppose the two-tiered WDRs and NPDES permit alternative, whereby an SSO occurring previously or in the future would trigger the requirement to apply for an NPDES permit, and agree with several points included in the Staff Report also opposing an NPDES permit. Since the existing SSS WDRs and the proposed revisions to the SSS WDRs do not authorize sanitary-sewer overflows (SSOs) to waters of the United States, there is no need for an NPDES permit. The question is what is to be gained through the addition of the NPDES permitting? Will it lead to a reduction in SSOs or provide increased protection of surface waters or waters of the State? We strongly recommend that staying within the framework of the SSS WDRs to achieve the objective to reduce SSOs and eliminate the threats to water quality.

As described in the Staff Report, this alternative would also require significant additional Water Board staff resources to track and implement the different permit tiers. We understand that these staff resources are limited, and believe that they should instead be used to further improve SSO reduction efforts under the existing SSS WDRs. By their very nature the SSS WDRs and NPDES requirements are for different purposes and imposing both on agencies will bring inherent contradictions and confusion for operating agencies.

We would also like to reinforce concerns about confusion and wasted resources resulting from adopting an NPDES permit component now, that may need to be revised again if the United States Environmental Protection Agency (USEPA) implements an NPDES permit for satellite sanitary sewer systems later. As a collection system operating in the San Francisco Bay Region, we can speak to this issue with experience; the 2006 statewide requirements included in the existing SSS WDRs were different from our established regional program. In developing our SSMP, we had to sift through and identify strategies that addressed *both* sets of requirements. Changes to reporting requirements made everything more confusing. As requirements become more complicated and confusing, more agency staff time is directed towards preparing reports and re-organizing information and operating procedures, and less time is spent actually managing or conducting the appropriate operations and maintenance (O&M) activities to prevent SSOs and properly maintain the collection system.

2. The basis for mandatory reporting of PLSDs is not justified and creates an inappropriate burden for public agency staff.

Water Board staff has not provided adequate justification to require public agencies to report PLSDs that are not affiliated with the collection system agency. State Water Board staff has simply not sufficiently thought through what this requirement means. It appears that State Water Board staff expects that collection system agencies are able to use limited public resources to investigate possible PLSDs. There is a clear separation between the collection agency responsibilities and private responsibilities for collection system operations.

Consider the "What ifs"... What if the collection system agency does not have access to all of the information for a PLSD, as requested on the reporting form? What if an agency receives a telephone report of a PLSD and from the information provided, the agency cannot determine the location? (Public resources should only be used to determine if there is an impact in the public rights-of-way that creates a public health risk or impacts waters of the State, not to hunt it down a purported PLSD.) How is the public agency supposed to estimate volume spilled or recovered? How will State Water Board staff enforce this provision? Most importantly, how will State Water Board staff use this information? We believe more research and discussion should be spent on this issue before including this additional requirement on collection agencies. There are many questions and very few answers or justifications addressed in the proposed revisions to the SSS WDRs. The State Water Board should only hold public agencies accountable and responsible for activities involving the agency collection system facilities and within the public realm.

Moreover, the Staff Report includes a reference to a study that indicated that the total volume of sewage from private laterals is about 5% of the total volume from SSOs, almost all of which never pose a threat to waters. Requiring public agencies to provide detailed information regarding such a small percentage of overflow volumes from parts of the system over which they have no control is not appropriate and would divert limited staff resources from higher priority issues that actually protect waters.

In addition, PLSDs typically only impact the property owner, as they are usually very small in volume and do not reach receiving waters. These types of events fall under the jurisdiction of local health officers. We recommend that the State Water Board first work with the California Department of Public Health and local environmental health officers to determine if the desired information can be obtained through mutual agency cooperation. We believe that public health agencies have the best knowledge of overflows from laterals on private property, and are, in most instances, the most appropriate agencies to respond to these events.

For all of the reasons indicated above, we specifically request that reporting of PLSDs remain voluntary.

3. It is essential that State and Regional Water Board staff consider the reasons for each SSO in any enforcement action.

The existing SSS WDRs included language in Provision D.6 that provided some reassurance that, in the case of an SSO enforcement action, the State and/or Regional Water Board would consider why the SSO might have occurred and to what extent it would have been reasonably possible for the Enrollee to prevent it.

Existing language read: *"In assessing these factors, the State and/or Regional Water Boards will also consider whether..."* (emphasis added)

In the proposed revisions to the SSS WDRs, this language was changed to read: *"In assessing these factors, the State and/or Regional Water Boards may also consider whether..."* (emphasis added)

The proposed revisions to the SSS WDRs would transform the existing enforcement discretion language, which expresses a clear statement of the State Board's intent regarding enforcement priorities and responses, into a purely advisory provision, which individual regional boards are free to follow or ignore as they choose. The factors described in (a) through (g) of Provision D.6 are highly relevant to the Enrollee's efforts to properly manage, operate and maintain its system and these factors should definitely be considered in enforcement actions.

It is imperative that the existing language be retained. Enrollees should not be made to suffer consequences for conditions that are outside their reasonable control.

4. Significant additional Sewer System Management Plan (SSMP) requirements should not be mandated until the State Water Board provides guidance and funding.

The proposed "Risk and Threat Analysis" and "Staff Performance Assessment Program" are vague, not statistically supported, unnecessarily complicated, and overly prescriptive.

The proposed Risk and Threat Analysis of all sanitary sewer assets would be complex and resource-intensive, and would not provide incrementally more benefit than that provided by an otherwise well-operated and managed system. It is not appropriate to require every agency to implement this requirement unless the Water Board can demonstrate that those agencies complying with current requirements have been ineffective in reducing SSOs. This program should also only be required if and when adequate Water Board guidance has been developed and funding is provided.

Requiring development and implementation of the proposed Staff Assessment Program on an agency-by-agency basis is unrealistic. The expectations outlined in the proposed revisions to the SSS WDRs suggest that agency staff would be responsible for developing a program similar to the existing Technical Certification Program offered by the California Water Environment Association, which would require a substantial investment of resources to do redundant work at each agency. It is also not appropriate to require public agencies to train contractors (which are separate, private entities).

The Water Board should not implement these new requirements until detailed program guidance is provided. Also, Water Board staff has not demonstrated that the current training requirements are deficient.

5. SSMP sections (i) and (j) should be combined, to remove redundant and contradictory language.

SSMP Section (i) *Performance Targets and Program Modifications* and Section (j) *SSMP Program Audits* both require the Enrollee to evaluate the effectiveness of the SSMP and correct or update the document as necessary. Section (i) indicates that this process is to occur on an annual basis, while Section (j) specifies a minimum frequency of once every two years. We recommend that Water Board staff combine these two sections and clarify the requirements.

Finding 9 in the proposed revisions to the SSS WDRs includes the statement: "Major causes of SSOs and PLSDs include but are not limited to: grease blockages, root blockages, debris blockages, sewer line flood damage, manhole structure failures, pipe failures, vandalism, pump station mechanical failures, power outages, excessive storm or ground water inflow/infiltration, sanitary sewer age, construction and related material failures, lack of proper operation and maintenance, insufficient capacity, and contractor-caused damages. Many SSOs and PLSDs can be prevented by having adequate facilities, source control measures, and proper operation and maintenance of the sanitary sewer system." Including PLSDs in these descriptions is incorrect: many of the items on the first list are not causes of PLSDs, and many PLSDs cannot be prevented as described in the second sentence. References to PLSDs should be removed.

Requiring de-chlorination of clean-up water is counter-productive.

Prohibition C.3 indicates that potable water would have to be de-chlorinated before it could be used for spill clean-up (in the event water used for clean-up is not fully recovered). Putting restrictions on the use of potable water in cleaning up an SSO that is otherwise likely to violate either of the first two prohibitions is impractical, particularly during emergency response. In addition, the amount of potable water used, combined with the distance it would have to travel to reach a surface water does not warrant the additional on-site operational difficulty in dechlorination.

Required reporting of PLSDs by all agencies does not improve the predicament faced by agencies that own lower laterals.

Requirements for reporting of SSOs are applicable to all "discharges resulting from a failure in the Enrollee's sanitary sewer system." (emphasis added) Requirements for reporting of PLSDs apply to all "discharges of wastewater resulting from a failure in a privately owned sewer lateral." (emphasis added) These requirements do not change the fact that SSOs from lower laterals are unfairly attributed only to those agencies that own them. In order to solve the problem, we

recommend that the CIWQS database and SSO/mile/yr data reflect *only* mainline spills as a performance measure. Otherwise, comparisons of these data among agencies are incorrect.

In addition, the requirement for Enrollees to report PLSDs as they become aware of should be removed from Provision 4.

It is inappropriate to use incomplete information about PLSDs to characterize sanitary sewer system condition and management.

We do not believe that meaningful statistics could be derived from data collected only for those PLSDs that an agency becomes aware of, and we do not support the idea that Water Board staff would decide that collection systems have "systemic issues" based on these incomplete data sets.

The requirement for Enrollees to report PLSDs they become aware of should be removed from Provision 4.

Revisions to SSMP requirements are premature.

We are concerned that the proposed revisions to the SSS WDRs include *significant* changes to SSMP program requirements. We strongly urge that the existing SSMP requirements be preserved as in the existing SSS WDRs. As the Staff Report indicates, development and implementation of SSMPs by SSS WDRs enrollees has just been completed and these plans need to be fully implemented so their effectiveness can be properly identified. Further, it is recognized that dramatically changing SSMP requirements before full implementation will likely lead to confusion regarding the SSMP requirements among enrollees, the public, and Water Board staff.

Language describing SSMP requirements should be revised as follows (SSMP sections are listed in the order they appear in the proposed revisions to the SSS WDRs):

- *Organization* - Including names, email addresses, and telephone numbers for the staff described in paragraph (b) (ii) is excessive information and inappropriate in a public document. Only the position and phone number should be included.
- *Legal Authority* – Paragraph (c) (v) should be revised to read: "Ban new connections under certain conditions." In addition, Paragraph (c) (vi) indicates that agencies must have legal authority to "limit the discharge of roots..." It is not clear if this phrase is intended to refer to limiting root intrusion (which would be covered by good standard specifications), or to limiting the illicit discharge of debris including cut roots (which is already included in paragraph (c) (i)). In any case, the word "roots" should be removed from this paragraph.
- *Operations and Maintenance Program*
 - *Map* - Updating sewer system maps to identify and include all backflow prevention devices would be too onerous as they are not owned by the agency; this requirement should be removed.

Also, the last section of paragraph (d) (i) should be revised to read: "A map illustrating the current extent of the sewer system shall be included in the SSMP or in a GIS." Also, this requirement needs to be clarified. It is not clear if "the current extent of the sewer system" refers to a one page map of the service area, or the entire detailed map. The latter would be impractical to include in the SSMP.

- *Rehabilitation and Replacement* - The third sentence in paragraph (d) (iii) should be revised to read: "Rehabilitation and replacement shall focus on sewer pipes that are at risk of collapse or prone to more frequent blockages due to pipe defects or do not meet capacity needs." It is not correct to imply that age alone is problematic. We know that it does not, nor is it correct to imply 'aging' is the same as 'deteriorating'.
- *O&M and Sewer System Replacement Funding* – The first sentence in section (d) (vi) should be revised to read "The SSMP shall include budgets for routine sewer system operation and maintenance and for the capital improvement plan including proposed replacement of sewer system assets over time as determined by careful evaluation of condition of the system."
- *Design and Performance Provisions* – The addition of the phrase "all aspects of" in both paragraphs (i) and (ii) should be removed; requiring each agency to update their standards and specifications to cover every last possible minor detail of sanitary sewer system construction and inspections just to meet this requirement would create an unwarranted burden on staff. Also, the phrase is not necessary and is already implied.
- *FOG Control Program* – Proposed revisions to (g) (iii) would simultaneously require legal authority to prohibit FOG discharges to the system and to require FOG dischargers to implement measures to prevent SSOs and blockages caused by FOG. This revised language contradicts itself, first by indicating that FOG discharges are to be prohibited, and then by including requirements for FOG dischargers. Also, the language appears to apply to both residential and commercial sources of FOG, but fails to recognize that logistical challenges may outweigh the benefits of *requiring* best management practices for residential FOG sources. We request that this existing language be preserved: "This plan shall include the following as appropriate:...The legal authority to prohibit discharges to the system and identify measures to prevent SSOs and blockages caused by FOG."
- *Performance Targets and Program Modifications* – Progress towards improving sewer system performance and reducing impacts of SSOs is already described in the SSMP and will be adequately characterized by a review of SSO trends. Also, without specific guidance on how to develop these targets, the requirement is vague and offers no validation of success or failure. All references to performance targets should be removed from paragraphs (i) and (j).
- *Communication Program* – The proposed revisions to the SSS WDRs would require each agency to communicate with the public on an annual basis regarding the development, implementation, and performance of its SSMP. This specified timeframe suggests that an agency would send out a notice of some sort at a certain time each year, but would not apply to agencies that communicate information to the public primarily via their websites; online information is made available 24 hours a day. The original language should be retained as is.

The four-year board re-certification requirement is excessive.

The proposed revisions to the SSS WDRs would also require each agency to bring its SSMP before its governing board for re-certification at a minimum every four years. This frequency is excessive considering that infrastructure projects typically occur over a longer timeframe. We request a re-certification every 5-10 years.

Notification requirements need to be clarified.

We support the Staff Report's indication that only Cal EMA would need to be notified when spills to surface water of any volume occur. However, Paragraph G.4 indicates that Enrollees are to provide immediate notification of SSOs to the local health officer or the local director of environmental health, contrary to the instructions indicated in Section A of the Monitoring and Reporting Program and the Staff Report. Please clarify that notification shall only to be made to Cal EMA, and indicate that Cal EMA will notify other agencies.

Certain Monitoring and Reporting Program requirements need to be clarified.


In addition to the request that mandatory PLSD reporting be removed from the proposed revisions to the SSS WDRs, several minor revisions should be made to clarify Monitoring and Reporting Program requirements:

- The second paragraph referring to other notification and reporting requirements is unnecessarily confusing and should be removed.
- Item 1.H under the description of mandatory information to be included in Category 2 SSO reports should be revised to read: "SSS failure point (main, lateral, etc.), if applicable."
- Item 3.I under the description of mandatory information to be included in Category 1 SSO reports should be revised to read: "Name of surface waters impacted (if applicable and if known)..."
- Item 1.D under the minimum records to be maintained by the Enrollee should be revised to read: "... and the complainant's name and telephone number if known."

In general, it is our view that significant proposed revisions to the SSS WDRs are premature and overly burdensome. Implementation of the existing permit has already successfully resulted in reduced impacts of SSOs on surface water. Additional improvements are expected as capital improvements identified under the current permit are completed. It would be frustrating to have invested significant resources in meeting the current requirements only to have them change before our current efforts have come to fruition. We believe that it would be more productive for the Water Board to focus on bringing all agencies into compliance with the current permit rather than initiating sweeping revisions that would apply to all agencies, regardless of compliance history or the effectiveness of current programs.

The City of Redwood City hopes that the State Water Resources Control Board will take these comments under serious consideration.

Sincerely,



Evan Boyd, Public Works Services Director
Legal Responsible Official

