

Matrix of ***Nonmetallic*** Pipe Monitoring Applications
 Gravity Flow, Vacuum (V), Pressure (P), and Interstitial Liquid Level Monitoring (ILLM)
 (Enclosure to State Water Board letter dated February 29, 2008; Matrix Updated September 30, 2009)

Nonmetallic Pipe Manufacturer		UL 971 pipe date stamped on or after July 1, 2005		
Brand	Secondary Containment Type and Size (Coaxial reported as ID of PS; SOS reported as OD of SC)	Fuels ⁶	Open (min. 5 psi rating on SC per UL)	Closed (min. 50 psi rating on SC per UL)
			Gravity Flow or Ambient ILLM	Vacuum, Pressure, or Pressurized ILLM
Ameron Dualoy 3000/L Dualoy 3000/LCX	Rigid; SOS; 3" & 4" Rigid; SOS; 6" Rigid; Coaxial (sticks); 2" & 3" Rigid; Coaxial (sticks); 4"	MV,CT,HB,AM MV,CT,HB,AM MV,CT,HB,AM MV,CT,HB,AM	Gravity Flow Gravity Flow Gravity Flow, AILLM ¹ Gravity Flow, AILLM ¹	V, P None V, P, PILLM ¹ None
Franklin Fueling/APT XP-150-SC XP-100, 175, 200	Flexible; Coaxial (coil); 1½" Flexible; Coaxial (coil); 1", 1¾", & 2"	MV,CT,HB,AM MV,CT,HB,AM	Gravity Flow Gravity Flow	V None
NUPI Smartflex	Flexible; Coaxial (coil); 2", 2½", & 5" Flexible; Coaxial (sticks); 2", 4" & 5"	MV,CT,HB,AM MV,CT,HB,AM	Gravity Flow Gravity Flow	V, P V, P
OPW-FCS C15, C20, C30 C75, C10⁴ PGFC-2150⁵	Flexible; Coaxial (coil); 1½", 2", & 3" Flexible; Coaxial (coil); ¾" & 1" Flexible; Coaxial (coil); 1½"	MV,AM MV,AM MV,AM	Gravity Flow Gravity Flow Gravity Flow	None V, P V, P
PetroTechnik UPP	Flexible; Coaxial (coil); 1½", 2" Flexible; Coaxial (sticks); 1½", 2", 3", 4"	MV,CT,HB,AM MV,CT,HB,AM	Gravity Flow Gravity Flow	V, P V, P
NOV Fiber Glass Systems Red Thread IIA	Rigid; SOS; 3" & 4" Rigid; SOS; 6"	MV,CT,HB,AM MV,CT,HB,AM	Gravity Flow Gravity Flow	V, P None
Western Fiberglass Co-Flex Co-Flex⁴ Co-Flex³	Flexible; Coaxial (coil); 1½", 2", & 3" Flexible; Coaxial (coil); ¾" & 1" Flexible; Coaxial (coil); 1½"	MV,AM MV, AM MV,AM	Gravity Flow, AILLM ² Gravity Flow, AILLM ² Gravity Flow, AILLM ²	None V, P, PILLM ² V, P, PILLM ²

1. Use only with Ameron's Brine Filled Interstitial Space Monitoring System (limited to maximum length of 344 feet).
2. Use only with Western Fiberglass Co-Flow Hydraulic Interstitial Monitoring System (limited to maximum length of 200 feet).
3. Procedures to verify the appropriate pipe for V or P applications include inspection in the field for a date stamp equal to or after November 30, 2006, and a marking of "50 PSI" on the secondary containment.
4. Procedures to verify the appropriate pipe for V and P applications include inspection in the field for a date stamp equal to or after January 29, 2008 and a marking of 50 PSI" on the secondary containment.
5. Procedures to verify the appropriate pipe for V or P applications include inspection in the field for a date stamp equal to or after November 16, 2006, and a marking of "50 PSI" on the secondary containment.
6. E85 is covered within the CT fuels testing range; therefore only pipe with the CT fuels marking can store E85.

Matrix of ***Metallic*** Pipe Monitoring Applications
 Gravity Flow, Vacuum (V), Pressure (P), and Interstitial Liquid Level Monitoring (ILLM)
(Enclosure to State Water Board letter dated February 29, 2008; Matrix Updated January 23, 2009)

Metallic Pipe Manufacturer		UL 971A		
Brand	Secondary Containment Type and Size (Coaxial reported as ID of PS; SOS reported as OD of SC)	Fuels	Open (min. 5 psi rating on SC per UL)	Closed (min. 50 psi rating on SC per UL)
			Gravity Flow or Ambient ILLM	Vacuum, Pressure, or Pressurized ILLM
Brugg Flexwell	Flexible; Coaxial (coil); 1½" & 2"	MV,CT,HB,AM	Gravity Flow	V, P
OmegaFlex DoubleTrac	Flexible; Coaxial (coil); 1", 1½", & 2"	MV,CT,HB,AM	Gravity Flow	V, P

Acronym	Definition
UL	Underwriters Laboratories Inc.
ID	Internal Diameter
OD	Outside Diameter
SOS	Size over Size
SC	Secondary Containment
V	Vacuum
P	Pressure
ILLM	Interstitial Liquid Level Monitoring
AILLM	Ambient Liquid Level Monitoring
PILLM	Pressurized Liquid Level Monitoring
MV	Motor Vehicle
CT	Concentrated
HB	High Blend
AM	Aviation & Marine

Acronyms used in the Matrix of Pipe Monitoring Applications