

Issue Date: April 15, 2022

Franklin Fueling Systems

**Franklin Fueling Systems EVO 200, EVO 400, EVO600, and EVO6000 with FMP-DIS-U
Discriminating Interstitial Sensor and FMP-EIS-U Electro-Optical Interstitial
Sensor**

INTERSTITIAL DETECTOR (LIQUID-PHASE)

Detector:

Output type: Qualitative

Sampling frequency: Continuous

Operating principle: float switch

Test Results:

	<u>unleaded gasoline</u>	<u>diesel</u>	<u>waste oil</u>	<u>water</u>	<u>E85</u>
FMP-DIS-U					
Detection time (min)	<1	<1	<1	<1	<1
Fall time (min)	<1	<1	<1	<1	<1
Threshold Level (in)	0.4293	0.4397	0.4208	0.4594	0.4240
FMP-EIS-U					
Detection time (min)	<1	<1	<1	<1	<1
Fall time (min)	<1	<1	<1	<1	<1
Threshold Level (in)	0.4478	0.4430	0.4317	0.4566	0.4507

Applicability:

California Code of Regulations require a written statement of compatibility for systems containing products other than those used in this evaluation.

Comments:

Sensors can be removed, cleaned and reinstalled if an alarm is triggered or if the sensor is periodically tested.

Franklin Fueling Systems

3760 Marsh Road

Evaluator: Ken Wilcox Associates

Tel: (816) 443-2494

Madison, WI 53718

Date of Evaluation: 05/02/2017, 11/8/2018

Tel: (800) 225-9787

email: info@franklinfueling.com

URL: www.franklinfueling.com

| [Home](#) | [Vendors: A - F](#) | [Vendors: G - M](#) | [Vendors: N - S](#) | [Vendors: T - Z](#) | [Method Index](#) |

Appearance on this list is not to be construed as an endorsement by any regulatory agency nor is it any guarantee of the performance of the method or equipment. Equipment should be installed and operated in accordance with all applicable laws and regulations. For full details, please refer to our expanded "[Disclaimer](#)" page.