



State Water Resources Control Board

UST CASE CLOSURE SUMMARY

Agency Information

Agency mornation	
Current Agency Name:	Address:
State Water Resources Control Board	1001 I Street, P.O. Box 2231
(State Water Board)	Sacramento, CA 95812
Agency Caseworker: Mr. Matthew Cohen	Case No.: Not Applicable
Former Agency Name:	Address:
Los Angeles County Department of Public Works	900 South Fremont Avenue
(Prior to 7/25/2013)	Alhambra, CA 91803
Agency Caseworker: Ms. Rani Iyer	Case No.: 010013-038366

Case Information

USTCF Claim No.: None	Global ID: T10000001253
Site Name:	Site Address:
ConocoPhillips Company No. 256150	2330 East Slauson Avenue
	Huntington Park, CA 90255 (Site)
Responsible Party:	Address:
Chevron Environmental Management Company	6101 Bollinger Canyon Road, Room 5307
Attention: Mr. Brett Hunter	San Ramon, CA 94583-5177
USTCF Expenditures to Date: Not applicable	Number of Years Case Open: 7

URL: http://geotracker.waterboards.ca.gov/profile report.asp?global id=T10000001253

Summary

The Low-Threat Underground Storage Tank Case Closure Policy (Policy) contains general and media-specific criteria, and cases that meet those criteria are appropriate for closure pursuant to the Policy. This case meets all of the required criteria of the Policy. Highlights of the Conceptual Site Model (CSM) upon which the evaluation of the case has been made are as follows:

The Site is an operating gasoline service station. All adjacent lots are developed for commercial use. The nearest public water supply well is located approximately 625 feet southeast from the Site. No other public water supply wells or surface water bodies exist within 1,000 feet of the Site. Groundwater has not been encountered at the Site to a maximum explored depth of 101.5 feet below ground surface (bgs). Estimated depth to groundwater is approximately 130 feet bgs near the Site.

Soil contamination was discovered during the site assessment conducted in 2007. Low concentrations of petroleum constituents are limited to soil between 5 to 66 feet bgs beneath the northern end of the tank pit and in the vicinity of the dispenser islands.

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR



The most current soil data obtained from the subsurface investigation in 2010 indicates that insignificant concentrations of petroleum constituents were detected in the low permeable soil between 51 to 66 feet bgs in the vicinity of the tank pit and dispenser islands. Petroleum constituents were non-detect in soil between 71 feet bgs to the maximum explored depth of 101.5 feet bgs. Historically, benzene has never been detected in any soil samples. Since 2007, 10 soil borings were advanced and 86 soil samples were collected and analyzed at the Site.

Residual petroleum constituents are limited to soil and vertical and horizontal limits of the plume are defined. Any remaining petroleum constituents do not pose significant risk to human health, safety, or the environment.

Rationale for Closure under the Policy

- General Criteria Site **MEETS ALL EIGHT GENERAL CRITERIA** under the Policy.
- Groundwater Media-Specific Criteria Site releases HAVE NOT AFFECTED GROUNDWATER. Groundwater has not been encountered to a maximum explored depth of 101.5 feet bgs. Soil does not contain sufficient mobile constituents (leachate, vapors, or light non-aqueous-phase liquids) to cause groundwater to exceed the groundwater criteria in this Policy.
- Petroleum Vapor Intrusion to Indoor Air Criteria Site meets the **EXCEPTION** for vapor intrusion to indoor air. The Site is an active petroleum fueling facility and has no release characteristics that can be reasonably believed to pose an unacceptable health risk.
- Direct Contact and Outdoor Air Exposure Criteria Site meets **CRITERIA (3) a.** Maximum concentrations of petroleum constituents in soil from confirmation soil samples are less than or equal to those listed in Table 1 of the Policy.

Recommendation for Closure

The corrective action performed at this Site ensures the protection of human health, safety, the environment and is consistent with chapter 6.7 of the Health and Safety Code and implementing regulations, applicable state policies for water quality control and the applicable water quality control plan, and case closure is recommended.

Prepared By: ______ Trinh Pham Water Resource Control Engineer

Reviewed By:

George Lockwood, PE#59556 Senior Water Resource Control Engineer

3/11/14

Date

3/11/14

Date

