

TO: Gene Schettler

SUBJECT: Appl 25224

DATE: 1-14-92

25224

M Enclosed are two Requests for License. Please have an authorized person
E sign and return one. The second is for the clips records. Also, need
S a picture of the completed weir. Please send so we can continue the license
S process. If you have any, questions, please contact me
A
G
E

RETURN TO

SIGNED

ADDRESS Box 2900, Sacto

PHONE 916-657-1935




*Thanks for
all your
help*

*This is constructed
as I told him. Will bypass
0.4 cfs prior to fully open*

RETURNED WITH REPLY

85 93594

Not to Scale



$$\begin{aligned} cfs &= 3.33 (L - 0.2H) H^{3/2} \\ &= 3.33 (1 - .056) .28^{3/2} \\ &= 0.47 cfs \quad \checkmark \end{aligned}$$

exceeds required 0.4 cfs bypass

Looking Upstream

WR-16