City of Murrieta
Department of Public Works
26442 Beckman Court
Murrieta, CA 92562
(909) 461-6068 • Fax: (909) 698-4509

INSPECTOR'S LOG

Date March 7, 2003 S M T W T F S (CIRCLE DAY OF WEEK) Page #

Weather clear / Low 70's

Auto Mall - placing AC, Regan Paving, in parking-lot area. Informed owner, Joe Herold, to provide civil certification for subgrade, base course, and paving elevations. Will also need soil compaction reports.

Ryland - Informed Super, Bob Williams, of non-compliance of NPDES requirements and not following BMP's. Told him I will write another correction notice if still in non-compliance by next Friday (17 Mar 03) 14 MAR

Curtis - Spraggins has completed utility trenches. Told super rain is forcast at end of the week and framers in the new area south of Santa Fe have put alot of soil in the gutters that needs to be cleaned-out and streets cleaned.

Granite - Cadell installing water line from ~~Scott~~ Rogers Way to top of Jefferson @ approximately 5½' deep. Informed foreman of need to install shoring / bench for ~~depths~~ depth exceeding 5'. Will comply.

KB - working on installing Edison in lateral's on Lincoln. Will take about another 2 weeks. Corrected traffic control signage.

[Signed] [signature] INSPECTOR

Knight Printing 1-800-523-0819 Reorder # COM-961530 - Rev 5/02