City of Murrieta
Department of Public Works
26442 Beckman Court
Murrieta, CA 92562
(909) 461-6068 • Fax: (909) 698-4509

INSPECTOR'S LOG

Date March 11, 2003 S M T W T F S (CIRCLE DAY OF WEEK) Page #

Weather clear/cool

Granite - pedestrian city-sidewalks being placed in phase VI. 1st & 2nd load 2500 psi instead of City Standard 3250 psi. Loads rejected.

Bepley-Near Cal - Super asked me to come look @ planned under sidewalk drains (5). Serval run into trees in parkway. Called Ken B to re-evolute plans. City does not want 25' of gravel swale between concrete lot swale + undersidewalk drain. Ken B instructed contractor to follow City Standard and have 2' wide channel made of concrete instead of rock.

Rancho Water - work on schedule

Salvation Army/Roel - Verbal warning follow-up to written NOC for NPDES. Silt fence not being maintained.

KB Homes - installing straw-mats of large boundary slopes in anticipation of more rain.

Ryland - continuing grading of Saratoga Springs - [No activity to comply with NPDES non-compliance]

Curtis/Ranchos - instructed super to clean gutters and clean street in construction zone

[Signed] Jay Pale
INSPECTOR

Knight Printing 1-800-523-0819 Reorder # COM-961530 - Rev 5/02