Table 1. Violation Summary for Kinder Morgan Energy Partners – SFPP, LP Mission Valley Terminal Wastewater Treatment System, January 2002 through June 2002.

Date of Violation	Violation	Permitted Limit	Reported Value	Pollutant Category	Ratio, Reported: Permitted	Serious/ Chronic	Water Code Section 13385	Penalty
Mar. 18-22, 2002	Chronic Toxicity – daily max.	1 TUc	4 TUc	N/A	N/A	Chronic	(i)(1)	---*
March 31, 2002	Total Phosphorus daily max.	0.2 mg/L	0.26 mg/L	1	1.3	Chronic	(i)(1)	---*
March 31, 2002	Total Phosphorus Average Monthly	0.1 mg/L	0.26 mg/L	1	2.6	Serious	(h)(1)	$3,000
May 6-10, 2002	Chronic Toxicity – daily max.	1 TUc	4 TUc	N/A	N/A	Chronic	(i)(1)	$3,000
May 6-10, 2002	Acute Toxicity –Instantaneous max.	0.59 TUa	1.54 TUa	N/A	N/A	Chronic	(i)(1)	$3,000
May 20-24, 2002	Chronic Toxicity – daily max.	1 TUc	2 TUc	N/A	N/A	Chronic	(i)(1)	$3,000
June 3-7, 2002	Chronic Toxicity – daily max.	1 TUc	2 TUc	N/A	N/A	Chronic	(i)(1)	$3,000
June 11, 2002	Manganese – Non-municipal/Non-potable Instantaneous Max.	0.05 mg/L	2.2 mg/L	2	44	Serious	(h)(1)	$3,000
June 24-28, 2002	Chronic Toxicity – daily max.	1 TUc	2 TUc	N/A	N/A	Chronic	(i)(1)	$3,000
							Total Penalty:	**$21,000**

* The Chronic violations of March 18-22, 2002 and March 31, 2002 do not incur a penalty of $3,000, because there are not three or more violations in the preceding 180-day period.

Ratio, Reported:Permitted is used for determining whether a violation is serious or chronic based on the category of the pollutant.